



**GENERAL NOTES**

1. ALL DIMENSIONS ARE GIVEN IN MILLIMETERS UNLESS OTHERWISE INDICATED.
2. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH THE SCOPE OF WORKS. ANY DISCREPANCIES ARE TO BE BROUGHT TO THE ATTENTION OF KELLIHERS FOR CLARIFICATION PRIOR TO ANY WORK COMMENCING.
3. CONTRACTOR TO FIELD VERIFY ALL DIMENSIONS, DISCREPANCIES ARE TO BE NOTIFIED TO THE CONTRACTOR AND DESIGN FOR RESOLUTION.
4. ALL WORKS TO COMPLY WITH PREVIOUSLY AGREED AND ISSUED SPECIFICATIONS
5. ALL EXTERNAL LIGHTING LAYOUTS ARE DESIGNED IN ACCORDANCE WITH BS5489:1-2020.

**LEGEND**

Site  
Results - Horizontal Illuminance (lux)  
Eav= 6.83  
Emin= 1.93  
Emax= 17.52  
Emin/Emax= 0.11  
Emin/Eav= 0.28  
Emax/Eav= 2.57

Mardyke street  
Results - Horizontal Illuminance (lux)  
Eav= 7.57  
Emin= 2.86  
Emax= 16.06  
Emin/Emax= 0.18  
Emin/Eav= 0.38  
Emax/Eav= 2.12

Luminaire Data  
Luminaire A BGP291 DM50 BL1 Lamp  
LED-HB 5.2S 730 MF 0.76  
  
Luminaire B BGP291 DN10 BL2 Lamp  
LED-HB 5.2S 730 MF 0.76

- Key
- Luminaire A Column
  - Luminaire B Column
  - Mast
  - Beam Aiming Target
  - Photometric Centre

All Dimensions in metres

ISSUED FOR COUNCIL APPROVAL		DMD	PS	PS	19FEB24
NO.	REVISION DESCRIPTION	DESIGN	CHECKED	APPROVED	DATE
<p>THIS DRAWING CONTAINS INFORMATION WHICH IS THE PROPERTY OF KELLIHERS LTD. THIS DRAWING IS PREPARED IN CONFIDENCE AND ITS CONTENTS MAY NOT BE DISCLOSED WITHOUT THE PRIOR WRITTEN CONSENT OF KELLIHERS LIMITED.</p>					
<p><b>PROJECT: SKIBEREEN GERIATRIC SOCIETY</b></p> <p><b>SGS APARTMENTS MARDYKE STREET SKIBEREEN LIGHTING LAYOUT PHILIPS LED</b></p>					
APPROVALS	DATE				
DESIGNED	DMD 19FEB24				
REVISION	DMD 19FEB24				
QUANTITY	PS 19FEB24				
CHECKED	-				
APPROVED	DMD 19FEB24				
ISSUED	PS 19FEB24				
REVISED	PS 19FEB24				
BY	PHILIPS				
FILE NO.	KE/SGS/01	PROJECT NO.	KE/SGS/01		
DATE	TO FIT	SCALE	1/100@A0		
SHEET	1	TOTAL SHEETS	1		